

The Water We Drink

The City of Kings Mountain, N.C
PWSID # NC 01-23-020

MARCH 22, 2017

Following is the Annual Water Quality Report for 2016. Our goal is to provide to you a safe and dependable supply of drinking water. Our water source is Moss Lake on the Clear Fork of Buffalo Creek. Moss Lake is a surface water source. The water supply for the City of Kings Mountain is sufficient for many years, and is of excellent quality. In our continuing efforts to maintain a safe and dependable water supply it will, from time to time, be necessary to make improvements in your water system. Costs of these improvements may be reflected in future rate structures.

If you have any questions about this report or concerning your water utility, please contact Newt Henson, Jr. at 704-482-7131 from 7:00AM until 3:00PM weekdays. We want our valued customers to be informed. If you want to learn more, please attend any of our regularly scheduled City Council meetings. They are held on the last Tuesday of each month at the Kings Mountain City Hall Council Chambers at 6:00 PM.

Kings Mountain monitors for more than 160 contaminants in our drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2016. The EPA and the State allow us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year.

What EPA Wants You to Know

Some people are more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have had organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Kings Mountain is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline, or at <http://www.epa.gov/safewater/lead>.

All drinking water, including bottled water, may be expected to contain at least small amounts of contaminants. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and in

some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. It is important to remember that the presence of these contaminants does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at 1-800-426-4791.

In this report you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Maximum Contaminant Level The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal the "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

What does all this mean?

We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water IS SAFE at these levels.

MCL's are set at very stringent levels. To help you understand the possible health effects described for many regulated constituents, a person would have to drink 1/2 gallon of water every day, at the MCL level, for a lifetime to have a one-in-a-million chance of having the described health effect.

We of the City of Kings Mountain water system work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

